catalogue.gira.com

GIRA Data sheet

© Copyright by Gira Giersiepen GmbH & Co. KG All rights reserved

www.gira.com

Heating actuator Basic, 6-gang for KNX

Specification	Order No.	Packing unit	£/piece without VAT	PS	EAN
DRA	2114 00	1	160.43	26	4010337018414

Features

- Heating actuator for switching thermal servos for heating systems or cooling ceilings.
- Control using 1-bit or 1-byte corrected variable telegrams.
- For 1-byte correcting variables, the outputs are controlled by pulse width modulation (PWM).
- Valve drives with the characteristic "de-energised open" or "de-energised closed" can be controlled.
- Servos with 24 V or 230 V rated voltage can be actuated.
- Overload protected, short-circuit-proof.
- Standard protection.
- Feedback via bus e.g. in the event of overload and short circuit.
- Switching the heating circuit pump (standard functions).
- Passive group feedback of the closed valve drives.

Technical data

KNX medium: TP256

Outputs: 6

Contact type: Triac

Power loss: max. 1 W

Switching voltage: AC 24/230 V, 50/60 Hz

Switching current: 5 to 160 mA

Switch-on current: max. 1.5 A (2 s)

Number of drives per output

- AC 230 V drives: 4 - AC 24 V drives: 2

Connection cross section: Max. 4 mm²

GIRA Data sheet

catalogue.gira.com

© Copyright by Gira Giersiepen GmbH & Co. KG All rights reserved

www.gira.com

- 4 -	

- Valves with the same operating voltage must be connected at all outputs. VDE approval in accordance with EN 60669-1, EN 60669-2-1.
- Installation on DIN top-hat rail.

Di	m	en	ısi	o	ทร
----	---	----	-----	---	----

Modular width (MW):

4